

## TEST REPORT

## Test Report Issued To:

AP LANKA (PVT) LTD.

416/5,LEYLAND ROAD,PANAGODA, HOMAGAMA, ,  
SRI LANKA 10200,  
HOMAGAMA, COLOMBO - 10200,  
SRI LANKA

Test Report No: A1M231028006/M231028006-11

Issue Date: 24-Nov-2023

Sample Booking/Receipt Date: 28-Oct-2023

Test Start Date: 04-Nov-2023

Test Completion Date: 06-Nov-2023



Customer Relationship Number 75488

## Sample Description :

MODIK Wall Mount Box Enclosure (WXHxD 250X300X150mm)



Customer Reference No :

MAIL DT.19/10/2023

Amendment Report to Test Report  
No:M231028006/M231028006-11 Dated:  
06-11-2023

Kind Attention : HARSHA DULIP

E-Mail: sales3@timikenlosures.com

Contact No: +947106005246

Sample Condition : Good

Sample Quantity (Approx) : 1 - Nos

Sample Size (Approx) : 250 X 300 X 150 - mm

SAMPLE NOT DRAWN BY OUR LABORATORY. THE RESULTS RELATE ONLY TO THE ITEMS TESTED



ULR-TC631423000012559F

Authencity of report can be verified by mail at [verification@spectrolab.in](mailto:verification@spectrolab.in)

This is a Digitally Signed Report and hence doesn't require Physical Signature.

Digitally signed by  
Surendra Kumar  
Date: 2023.11.24  
14:35:29 +05'30  
SPECTROLAB

Report Issued By

Legal Entity: Spectro Analytical Labs Private Limited (formerly Spectro Analytical Labs Limited), CIN : U74220DL1998PTC092698  
(part of Eurofins Scientific SE)

## TEST REPORT

Discipline Name: **Electrical**Group Name: **Environmental test facility****1. DEGREE OF PROTECTION AGAINST MECHANICAL IMPACTS IK-08**

1. Test Specification: - IEC 62262: 2002
2. Reference Test Method: - IEC 60068-2-75: 2014
3. IK Code: - IK 08
4. Ambient Condition: - Temperature: 26°C & Air pressure: 978 mbar
5. Impact Energy: - 5 Joules
6. Test Equipment: - Free fall hammer
7. No. of specimen: - 1
8. Support: - The enclosure was mounted on a rigid support
9. Striking Hammer: - Height of fall: 300 mm & Equivalent weight: 1700 gm
10. Application of blows/impacts: - 5 impacts on each exposed face. The impacts were evenly distributed on the faces of the enclosures.

**11. Observations: - No admissible damage observed after the test.****12. Remark: - "PASS"**

Photograph	
	
Sample Before Test	Sample After Test



Analyst Signature

TC-6314

ULR-TC631423000012559F

Authorised Signatory

Legal Entity: Spectro Analytical Labs Private Limited (formerly Spectro Analytical Labs Limited), CIN : U74220DL1998PTC092698  
 (part of Eurofins Scientific SE)